

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50155488

Blatt *Page*
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*
05-YW- 16009953 002

Ausstellungsdatum
21.05.2009

Date of Issue
(day/mo/yr)


Genehmigungsinhaber *License Holder*

Honest-Well Co., Ltd.
3F., No.450, Sec 2
Chung Shān Road
Chung Ho, Taipei 235
Taiwan

Fertigungsstätte *Manufacturing Plant*

05-SLE-16009953 001

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

EN 60730-1:2000+A1+A12+A13+A14+A15
EN 60730-2-9:2002+A1+A2+A11+A12

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Temperatur-Regler (Thermal Cut-out)

Type Designation : H2M/33
Rated Voltage : AC 250V; 50-60Hz
Rated Current : 16A (Resistive)
Operation Cycles : 6,000
Switching Temperature : 45°C - 180°C
Reset Type : Manual Reset
Max. Temperature of Switching Head : 185°C
Manufacturing Deviation : 5%
Drift : ±5%
Degree of Protection : IP00
Degree of Pollution : 3
Construction : Incorporated Control, for Class I Equipment
Action Type : 2B
Rated Impulse Voltage : 2500V

Remark: The labelling requirements acc. to EU Directive to be observed for distribution 2001/95 have within the EEA.



5

5

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland Product Safety GmbH, Am Grauen Stein, D-51105 Köln
Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com
Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

Zertifizierungsstelle

Dipl.-Ing. (FH) T. Zimmer