

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50276743

Blatt *Page*
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*

Ausstellungsdatum

Date of Issue
(day/month/year)

05-LJP- 02154270 008

21.02.2014

Genehmigungsinhaber *License Holder*

Honest-Well Co., Ltd.
No.448, Sec.2, Chung-San Rd.
Chung-Ho District
New Taipei City 235
Taiwan

Fertigungsstätte *Manufacturing Plant*

05-LY-02154270 004

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 2000000000

Geprüft nach *Tested acc. to*

EN 60730-1:2000+A1+A2+A12+A13+A14+A16

EN 60730-2-9:2010

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Temperature Control (Thermostat)

Type Designation : H2M/11
Trademark : Honest-Well (logo)
Rated Voltage : AC 250V; 50-60Hz
Rated Current : 10 or 16A
Switching Temperature : 0°C-180°C
Ambient Temperature : 0°C-180°C
Operation Cycles : 10,000 (Manual reset)
Construction : Incorporated Control, for
Class I or Class II Equipment
Degree of Pollution : 2
Action Type : 2.B
Proof Tracking Index : PTI 175
Rated Impulse Voltage : 2500V
Resistance to Heat and Fire : Category D
Manufacturing deviation : ±10°C
Drift : ±10°C

5

Remark : The labelling requirements acc. to EU Directive 2001/95 have to be observed for distribution within the EEA. The installation has to be carried out according to installation instruction accompanying the products.

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg
Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com
Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

Zertifizierungsstelle



Dipl.-Ing. (FH) T. Zimmer